

Department of Aerospace Engineering

IIT Kanpur

March 19, 2012

Enquiry No. AE/Vilab/2012002

Closing Date: March 26, 2012

Enquiry for UPS

Formal quotations are invited for UPS (Qty - 01). Specifications of the UPS is given below –

| |
|---|
| Type - True online, double conversion type, digital UPS systems |
| Backup – 1 Hour |
| Capacity – 10 KVA and 12 KVA |
| Input – 3-phase 400V (330-470VAC) |
| Output- Single Phase 220/230VAC \pm 1%, 2 Wire +E |
| Output short circuit protection |

Terms and conditions

- The quotation must reach the undersigned on or before 5 :00 PM, March 26, 2012
- Quotation should be valid for 30 days
- The right to reject all or any of the quotations or relax any condition without assigning any reason is reserved

Please send your sealed quotation at following address-

Alok Gupta

Department of Aerospace Engineering

Indian Institute of Technology Kanpur

Kanpur-20801(6U P)

Ph: 0512-2597050, Fax: 05 12-2597626, e-mail:alokg@iitk.ac.in

Thank you



Alok Gupta