

**INDIAN INSTITUTE OF TECHNOLOGY KANPUR
DEPARTMENT OF PHYSICS**


Addendum to make of UPS and VAH of Batteries

Ref: Enquiry No. IITK/PHY/64 dt.06/06/2012

With reference to the above enquiry released on 06/06/2012, the following modification is hereby made.

1. Make of UPS : Nemerick/Delta/Emersion/APC/Eatan/GE/Socomec/BPE/PCI
2. VAH : minimum 24000 VAH for 45 minutes.
minimum 16000 VAH for 30 minutes

Other items and terms & conditions remain unchanged.



(Head)
Department of Physics
IIT Kanpur