

INDIAN INSTITUTE OF TECHNOLOGY KANPUR
Department of Earth Sciences

***REVISED**

Enquiry No: ES/IS/Init/2014-15/02

Date: 02.06.2015

Subject: Quotation for supply Portable Generator Honda make as mentioned below.

With reference to the subject mentioned above, you are invited to submit the quotation in a sealed cover in order to reach us by **June 10th, 2015** in the form of a hard copy to the address mentioned below. If you have any questions please call Dr.I.S.Sen at 0512-259-6440, email: isen@iitk.ac.in.

Technical Specification for Portable generator (Quantity 01):-

- AC Output Rated Voltage : 230V
 Rated Frequency: 50 Hz
 Rated Ampere : 7 - 8 A
 Rated Output : 1.8 KVA
 Max. Output : 2.1 KVA

- The weight of the generator (Dry Mass) should not be more than 92 Kg.
- The engine Type should be 4 Stroke, Overhead Valve, and Single Cylinder.
- The Ignition System should be Transistorized Magneto Ignition.
- It should have the fuel tank capacity between 9 to 10 L.
- It should have a forced air cooling system.
- Warranty should not be less than 1 years on parts.

Terms and Conditions:-

1. Maximum education discount, if any should be offered
2. Validity of quotation should be at least for 60 days
3. Prices should be on FOB separately (if imported)
4. Prices should include the installation and training cost
5. Normal payment terms for the Institute will be applicable (90% on delivery of the items and the remaining 10% after satisfactory installation/ inspection).
6. Quotation should carry proper certifications like agency certificate, proprietary certificate, etc.
7. Delivery should be made within 1 month.

Dr.I.S.Sen
WLE 202, Earth Sciences Department
I.I.T. Kanpur PIN 208016